

hill construction group, inc.

1129 middletown road
Andover, vt 05143
802-875-1407
swhill@vermontel.net

October 5,, 2020

The Town of Windham VT
5976 Windham Hill Road
Windham, VT 05359

SAND PRICES 2020/21 SEASON

FOB Adams Pit: \$13.50 per yard

DELIVERED (through October 31st, 2020): \$16.50 per yard

DELIVERED (after December 1st, as needed): \$17.50 per yard

-Sand analysis provided is one we have on hand for $\frac{3}{8}$ " minus mound sand.

- The Winter Sand would be similar except the largest stone would be $\frac{3}{4}$ " minus resulting in coarse sand.

CONCRETE BLOCK DELIVERY PRICE

2' x'2 x 6' concrete block delivered to Windham Town Garage from Shaftsbury:

- 10 block load: \$ 400.00 (delivery only)

M&W SOILS ENGINEERING, INC

SOILS AND CONCRETE LABORATORIES

159 East Street
 PO Box 1466
 Charlestown, NH 03603
 603-826-5873

MECHANICAL ANALYSIS OF AGGREGATES AND GRANULAR MATERIAL

Project: **HILL CONSTRUCTION GROUP**

Type of Material: Mound Sand	Sample #:	420VTSand
Source of Material: Hill Pit	Date in Lab:	4-20-20
Sample from: Delivered by client	Date Tested:	4-22-20
Report To: HCG Inc.	Technician:	R. Rhoades

Sieve	Weight	% Retained	Cumulative % Retained	Cumulative % Finer	Specification (Mound Sand 1)	ASTM C-33, VT Presby Sand	Specification (Mound Sand 3)
1/2"	0.0	0.0	0.0	100.0			
3/8"	0.0	0.0	0.0	100.0	85-100	100	85-100
4	16.1	3.2	3.2	96.8		95-100	
8	39.1	7.8	11.0	89.0		80-100	
10	15.1	3.0	14.0	86.0			
16	61.7	12.3	26.2	73.8		50-85	
30	181.2	36.0	62.2	37.8		25-60	
40	75.0	14.9	77.1	22.9	25-75		30-50
50	37.2	7.4	84.5	15.5		10-30	
60	22.3	4.4	88.9	11.1	0-30		
100	36.0	7.1	96.1	3.9	0-10	2-10	
200	12.5	2.5	98.6	1.4	0-5	0-3	0-5
pan	7.3	1.4	100.0	0.0			

Moisture Content: 4.3 %

This sample meets the gradation requirements of VT Mound Sand 2 (C-33 sand), and meets the requirements as Presby System Sand in VT